



Erratum

Erratum to “Simple analytic rules for model reduction and PID controller tuning”

[J. Process Control, vol. 13 (2003), 291–309]<sup>☆</sup>

Sigurd Skogestad

*Department of Chemical Engineering, Norwegian University of Science and Technology (NTNU), N7491 Trondheim, Norway*

The following misprints in the paper need to be corrected:

- page 293, Eq. (9). Add the Laplace variable  $s$  before  $+$  in the numerator.
- page 294, Eq. (12). Denominator in Rule T3 should be  $(\tilde{\tau}_0 - T_0)s + 1$ , i.e.,  $\tau_0$  should be replaced by  $T_0$ .
- page 302, Table 6. The heading of column 2 should be  $K_c \cdot k$  (and not  $K_c \cdot k'$ ).
- page 302, Table 6, The heading of column 3 should be  $K_I \cdot k \cdot \theta$  (and not  $K_I \cdot \tau_I/\theta$ ).

<sup>☆</sup> doi of original article: [10.1016/S0959-1524\(02\)00062-8](https://doi.org/10.1016/S0959-1524(02)00062-8).

E-mail address: [skoge@chemeng.ntnu.no](mailto:skoge@chemeng.ntnu.no) (S. Skogestad).